

Analytical Report

Warren Chestang
South Holland School District 151
525 E 162nd St
South Holland, IL 60473

September 18, 2017


Work Order: 1710351

RE: Drinking Water Analysis
Coolidge School

Dear Warren Chestang:

Enclosed are the analytical reports for the EMT Work Order listed. Also included with this analytical report is a copy of the chain of custody associated with these samples. If you have any questions, please contact me.

Sincerely,



Tim Witrzek
Project Manager
847.967.6666

Approved by,



Matthew Gregory
Technical Manager

Approved for release: 9/18/2017 10:15:19AM

The contents of this report apply to the sample(s) analyzed. No duplication is allowed except in its entirety. Reporting limits are adjusted for sample size used, dilutions and moisture content, if applicable.

State of Illinois, NELAP Accredited Lab No. 100256, Cert No. 003674



Table of Contents

Cover Letter	1
Case Narrative	3
Client Sample Results	5
Qualifiers and Definitions	16
Certified Analyses	16
List of Certifications	17
Chain of Custody	18

Case Narrative

Client: South Holland School District 151

Date: 09/18/2017

Project: Drinking Water Analysis

Coolidge School

Work Order: 1710351

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

Sample Summary

Sample ID	Laboratory ID	Matrix	Date Sampled	Last Time Used:	Date Received
C1-1 FIRST DRAW	1710351-01	Drinking Water	09/07/17 06:30	09/06/17 21:00	09/11/17 16:20
C1-2 SECOND DRAW	1710351-02	Drinking Water	09/07/17 06:30	09/06/17 21:00	09/11/17 16:20
C2-1 1ST	1710351-03	Drinking Water	09/07/17 06:34	09/06/17 21:00	09/11/17 16:20
C2-1 2ND	1710351-04	Drinking Water	09/07/17 06:34	09/06/17 21:00	09/11/17 16:20
C4-1 1ST	1710351-05	Drinking Water	09/07/17 06:38	09/06/17 21:00	09/11/17 16:20
C4-2 2ND	1710351-06	Drinking Water	09/07/17 06:38	09/06/17 21:00	09/11/17 16:20
C5-1 1ST	1710351-07	Drinking Water	09/07/17 06:40	09/06/17 21:00	09/11/17 16:20
C5-2 2ND	1710351-08	Drinking Water	09/07/17 06:40	09/06/17 21:00	09/11/17 16:20
C6-1 1ST	1710351-09	Drinking Water	09/07/17 06:42	09/06/17 21:00	09/11/17 16:20
C6-2 2ND	1710351-10	Drinking Water	09/07/17 06:42	09/06/17 21:00	09/11/17 16:20
C7-1 1ST	1710351-11	Drinking Water	09/07/17 06:44	09/06/17 21:00	09/11/17 16:20
C7-2 2ND	1710351-12	Drinking Water	09/07/17 06:44	09/06/17 21:00	09/11/17 16:20
C8-1 1ST	1710351-13	Drinking Water	09/07/17 06:45	09/06/17 21:00	09/11/17 16:20
C8-2 2ND	1710351-14	Drinking Water	09/07/17 06:45	09/06/17 21:00	09/11/17 16:20
C9-1 1ST	1710351-15	Drinking Water	09/07/17 06:47	09/06/17 21:00	09/11/17 16:20
C9-2 2ND	1710351-16	Drinking Water	09/07/17 06:47	09/06/17 21:00	09/11/17 16:20
C10-1 1ST	1710351-17	Drinking Water	09/07/17 06:49	09/06/17 21:00	09/11/17 16:20
C10-2 2ND	1710351-18	Drinking Water	09/07/17 06:49	09/06/17 21:00	09/11/17 16:20
C11-1 1ST	1710351-19	Drinking Water	09/07/17 06:50	09/06/17 21:00	09/11/17 16:20
C11-2 2ND	1710351-20	Drinking Water	09/07/17 06:50	09/06/17 21:00	09/11/17 16:20
C12 1ST	1710351-21	Drinking Water	09/07/17 06:50	09/06/17 21:00	09/11/17 16:20
C12 2ND	1710351-22	Drinking Water	09/07/17 06:50	09/06/17 21:00	09/11/17 16:20
C13 1ST	1710351-23	Drinking Water	09/07/17 06:51	09/06/17 21:00	09/11/17 16:20
C13 2ND	1710351-24	Drinking Water	09/07/17 06:51	09/06/17 21:00	09/11/17 16:20
C14 1ST	1710351-25	Drinking Water	09/07/17 06:52	09/06/17 21:00	09/11/17 16:20
C14 2ND	1710351-26	Drinking Water	09/07/17 06:52	09/06/17 21:00	09/11/17 16:20
C15 1ST	1710351-27	Drinking Water	09/07/17 06:53	09/06/17 21:00	09/11/17 16:20
C15 2ND	1710351-28	Drinking Water	09/07/17 06:53	09/06/17 21:00	09/11/17 16:20
C16 1ST	1710351-29	Drinking Water	09/07/17 06:54	09/06/17 21:00	09/11/17 16:20
C16 2ND	1710351-30	Drinking Water	09/07/17 06:54	09/06/17 21:00	09/11/17 16:20
C17 1ST	1710351-31	Drinking Water	09/07/17 06:55	09/06/17 21:00	09/11/17 16:20
C17-2 2ND	1710351-32	Drinking Water	09/07/17 06:55	09/06/17 21:00	09/11/17 16:20
C18-1 1ST	1710351-33	Drinking Water	09/07/17 06:56	09/06/17 21:00	09/11/17 16:20
C18-2 2ND	1710351-34	Drinking Water	09/07/17 06:56	09/06/17 21:00	09/11/17 16:20
C19-1 1ST	1710351-35	Drinking Water	09/07/17 06:30	09/06/17 21:00	09/11/17 16:20

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

C19-2 2ND	1710351-36	Drinking Water	09/07/17 06:31	09/06/17 21:00	09/11/17 16:20
C20-1 1ST	1710351-37	Drinking Water	09/07/17 06:32	09/06/17 21:00	09/11/17 16:20
C-20 2 2ND	1710351-38	Drinking Water	09/07/17 06:33	09/06/17 21:00	09/11/17 16:20
C21-1 1ST	1710351-39	Drinking Water	09/07/17 06:34	09/06/17 21:00	09/11/17 16:20
C21-2 2ND	1710351-40	Drinking Water	09/07/17 06:35	09/06/17 21:00	09/11/17 16:20
C22-1 1ST	1710351-41	Drinking Water	09/07/17 06:35	09/06/17 21:00	09/11/17 16:20
C22-2 2ND	1710351-42	Drinking Water	09/07/17 06:37	09/06/17 21:00	09/11/17 16:20
C23-1 1ST	1710351-43	Drinking Water	09/07/17 06:40	09/06/17 21:00	09/11/17 16:20
C23-2 2ND	1710351-44	Drinking Water	09/07/17 06:41	09/06/17 21:00	09/11/17 16:20
C24-1 1ST	1710351-45	Drinking Water	09/07/17 06:41	09/06/17 21:00	09/11/17 16:20
C24-2 2ND	1710351-46	Drinking Water	09/07/17 06:42	09/06/17 21:00	09/11/17 16:20
C25-1 1ST	1710351-47	Drinking Water	09/07/17 06:46	09/06/17 21:00	09/11/17 16:20
C25-2 2ND	1710351-48	Drinking Water	09/07/17 06:47	09/06/17 21:00	09/11/17 16:20
C26-1 1ST	1710351-49	Drinking Water	09/07/17 06:48	09/06/17 21:00	09/11/17 16:20
C26-2 2ND	1710351-50	Drinking Water	09/07/17 06:49	09/06/17 21:00	09/11/17 16:20
C27-1 1ST	1710351-51	Drinking Water	09/07/17 06:53	09/06/17 21:00	09/11/17 16:20
C27-2 2ND	1710351-52	Drinking Water	09/07/17 06:54	09/06/17 21:00	09/11/17 16:20
C28-1 1ST	1710351-53	Drinking Water	09/07/17 06:56	09/06/17 21:00	09/11/17 16:20
C28-2 2ND	1710351-54	Drinking Water	09/07/17 06:57	09/06/17 21:00	09/11/17 16:20
C29-1 1ST	1710351-55	Drinking Water	09/07/17 06:59	09/06/17 21:00	09/11/17 16:20
C29-2 2ND	1710351-56	Drinking Water	09/07/17 07:00	09/06/17 21:00	09/11/17 16:20
C30-1 1ST	1710351-57	Drinking Water	09/07/17 07:03	09/06/17 21:00	09/11/17 16:20
C30-2 2ND	1710351-58	Drinking Water	09/07/17 07:04	09/06/17 21:00	09/11/17 16:20
C31-1 1ST	1710351-59	Drinking Water	09/07/17 07:05	09/06/17 21:00	09/11/17 16:20
C31-2 2ND	1710351-60	Drinking Water	09/07/17 07:07	09/06/17 21:00	09/11/17 16:20
C32-1 1ST	1710351-61	Drinking Water	09/07/17 07:09	09/06/17 21:00	09/11/17 16:20
C32-2 2ND	1710351-62	Drinking Water	09/07/17 07:10	09/06/17 21:00	09/11/17 16:20
C33-1 ST	1710351-63	Drinking Water	09/07/17 07:15	09/06/17 21:00	09/11/17 16:20
C33-2 2ND	1710351-64	Drinking Water	09/07/17 07:16	09/06/17 21:00	09/11/17 16:20
C34-1	1710351-65	Drinking Water	09/07/17 07:17	09/06/17 21:00	09/11/17 16:20
C34-2	1710351-66	Drinking Water	09/07/17 07:18	09/06/17 21:00	09/11/17 16:20
C35-1	1710351-67	Drinking Water	09/07/17 07:19	09/06/17 21:00	09/11/17 16:20
C35-2	1710351-68	Drinking Water	09/07/17 07:20	09/06/17 21:00	09/11/17 16:20

Narrative

Sample results only relate to the to the sample received at the laboratory and analytes of interest tested.

Work Order: 1710351

The samples were received on 09/11/17 16:20. The samples arrived in good condition and properly preserved. The temperature of the cooler at receipt was

<u>Cooler</u>	<u>Temp C°</u>
Default Cooler	5.2

Refer to Qualifiers and Definitions for quality and analytical clarifications or deviations.

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Client Sample Results

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C1-1 FIRST DRAW Collection Date: 9/7/2017 6:30:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-01		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 13:29	B710423	AG
Client Sample ID: C1-2 SECOND DRAW Collection Date: 9/7/2017 6:30:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-02		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 13:30	B710423	AG
Client Sample ID: C2-1 1ST Collection Date: 9/7/2017 6:34:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-03		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 13:31	B710423	AG
Client Sample ID: C2-1 2ND Collection Date: 9/7/2017 6:34:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-04		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 13:33	B710423	AG
Client Sample ID: C4-1 1ST Collection Date: 9/7/2017 6:38:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-05		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 13:34	B710423	AG
Client Sample ID: C4-2 2ND Collection Date: 9/7/2017 6:38:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-06		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 13:35	B710423	AG

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C5-1 1ST Collection Date: 9/7/2017 6:40:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-07		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 13:39	B710423	AG
Client Sample ID: C5-2 2ND Collection Date: 9/7/2017 6:40:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-08		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 13:40	B710423	AG
Client Sample ID: C6-1 1ST Collection Date: 9/7/2017 6:42:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-09		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 13:41	B710423	AG
Client Sample ID: C6-2 2ND Collection Date: 9/7/2017 6:42:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-10		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 13:42	B710423	AG
Client Sample ID: C7-1 1ST Collection Date: 9/7/2017 6:44:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-11		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 13:43	B710423	AG
Client Sample ID: C7-2 2ND Collection Date: 9/7/2017 6:44:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-12		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 13:45	B710423	AG

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C8-1 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:45:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-13		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 13:46	B710423	AG
Client Sample ID: C8-2 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:45:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-14		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 13:47	B710423	AG
Client Sample ID: C9-1 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:47:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-15		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 13:59	B710448	AG
Client Sample ID: C9-2 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:47:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-16		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:00	B710448	AG
Client Sample ID: C10-1 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:49:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-17		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:01	B710448	AG
Client Sample ID: C10-2 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:49:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-18		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:03	B710448	AG

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C11-1 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:50:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-19		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:04	B710448	AG
Client Sample ID: C11-2 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:50:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-20		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:05	B710448	AG
Client Sample ID: C12 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:50:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-21		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:09	B710448	AG
Client Sample ID: C12 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:50:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-22		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:10	B710448	AG
Client Sample ID: C13 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:51:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-23		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:11	B710448	AG
Client Sample ID: C13 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:51:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-24		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:12	B710448	AG

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C14 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:52:00AM					Last Time Used: 9/6/2017 9:00:00PM	Lab ID: 1710351-25		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:13	B710448	AG
Client Sample ID: C14 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:52:00AM					Last Time Used: 9/6/2017 9:00:00PM	Lab ID: 1710351-26		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:15	B710448	AG
Client Sample ID: C15 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:53:00AM					Last Time Used: 9/6/2017 9:00:00PM	Lab ID: 1710351-27		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:16	B710448	AG
Client Sample ID: C15 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:53:00AM					Last Time Used: 9/6/2017 9:00:00PM	Lab ID: 1710351-28		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:17	B710448	AG
Client Sample ID: C16 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:54:00AM					Last Time Used: 9/6/2017 9:00:00PM	Lab ID: 1710351-29		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:18	B710448	AG
Client Sample ID: C16 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:54:00AM					Last Time Used: 9/6/2017 9:00:00PM	Lab ID: 1710351-30		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:19	B710448	AG

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C17 1ST Collection Date: 9/7/2017 6:55:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-31		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:23	B710448	AG
Client Sample ID: C17-2 2ND Collection Date: 9/7/2017 6:55:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-32		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:24	B710448	AG
Client Sample ID: C18-1 1ST Collection Date: 9/7/2017 6:56:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-33		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:26	B710448	AG
Client Sample ID: C18-2 2ND Collection Date: 9/7/2017 6:56:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-34		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:27	B710448	AG
Client Sample ID: C19-1 1ST Collection Date: 9/7/2017 6:30:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-35		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:38	B710449	AG
Client Sample ID: C19-2 2ND Collection Date: 9/7/2017 6:31:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-36		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:39	B710449	AG

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C20-1 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:32:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-37		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:41	B710449	AG
Client Sample ID: C-20 2 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:33:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-38		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:42	B710449	AG
Client Sample ID: C21-1 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:34:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-39		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:43	B710449	AG
Client Sample ID: C21-2 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:35:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-40		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:44	B710449	AG
Client Sample ID: C22-1 1ST						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:35:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-41		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:45	B710449	AG
Client Sample ID: C22-2 2ND						Matrix: Drinking Water		
Collection Date: 9/7/2017 6:37:00AM		Last Time Used: 9/6/2017 9:00:00PM				Lab ID: 1710351-42		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:47	B710449	AG

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C23-1 1ST Collection Date: 9/7/2017 6:40:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-43		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 14:48	B710449	AG
Client Sample ID: C23-2 2ND Collection Date: 9/7/2017 6:41:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-44		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 14:49	B710449	AG
Client Sample ID: C24-1 1ST Collection Date: 9/7/2017 6:41:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-45		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	6.91	2.00			ppb	09/14/17 14:53	B710449	AG
Client Sample ID: C24-2 2ND Collection Date: 9/7/2017 6:42:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-46		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	3.07	2.00			ppb	09/14/17 14:54	B710449	AG
Client Sample ID: C25-1 1ST Collection Date: 9/7/2017 6:46:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-47		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 14:55	B710449	AG
Client Sample ID: C25-2 2ND Collection Date: 9/7/2017 6:47:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-48		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 14:56	B710449	AG

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C26-1 1ST Collection Date: 9/7/2017 6:48:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-49		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:58	B710449	AG
Client Sample ID: C26-2 2ND Collection Date: 9/7/2017 6:49:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-50		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 14:59	B710449	AG
Client Sample ID: C27-1 1ST Collection Date: 9/7/2017 6:53:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-51		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:00	B710449	AG
Client Sample ID: C27-2 2ND Collection Date: 9/7/2017 6:54:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-52		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:01	B710449	AG
Client Sample ID: C28-1 1ST Collection Date: 9/7/2017 6:56:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-53		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:03	B710449	AG
Client Sample ID: C28-2 2ND Collection Date: 9/7/2017 6:57:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-54		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:04	B710449	AG

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C29-1 1ST Collection Date: 9/7/2017 6:59:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-55		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:15	B710450	AG
Client Sample ID: C29-2 2ND Collection Date: 9/7/2017 7:00:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-56		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:16	B710450	AG
Client Sample ID: C30-1 1ST Collection Date: 9/7/2017 7:03:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-57		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:17	B710450	AG
Client Sample ID: C30-2 2ND Collection Date: 9/7/2017 7:04:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-58		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:18	B710450	AG
Client Sample ID: C31-1 1ST Collection Date: 9/7/2017 7:05:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-59		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:22	B710450	AG
Client Sample ID: C31-2 2ND Collection Date: 9/7/2017 7:07:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-60		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:23	B710450	AG

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C32-1 1ST Collection Date: 9/7/2017 7:09:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-61		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 15:24	B710450	AG
Client Sample ID: C32-2 2ND Collection Date: 9/7/2017 7:10:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-62		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 15:26	B710450	AG
Client Sample ID: C33-1 ST Collection Date: 9/7/2017 7:15:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-63		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 15:27	B710450	AG
Client Sample ID: C33-2 2ND Collection Date: 9/7/2017 7:16:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-64		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 15:28	B710450	AG
Client Sample ID: C34-1 Collection Date: 9/7/2017 7:17:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-65		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 15:30	B710450	AG
Client Sample ID: C34-2 Collection Date: 9/7/2017 7:18:00AM Collection Volume: 250 ml bottle						Matrix: Drinking Water Lab ID: 1710351-66		
Last Time Used: 9/6/2017 9:00:00PM								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00		U	ppb	09/14/17 15:31	B710450	AG

8100 N. Austin Avenue Morton Grove, IL 60053-3203 P 847.967.6666 800.246.0663 F 847.967.6735 www.emt.com

Client Sample Results

(Continued)

Client: South Holland School District 151
Project: Drinking Water Analysis
 Coolidge School
Work Order: 1710351

Report Date: 09/18/2017

Analyses	Result	EMT Reporting		Qual	Units	Date/Time Analyzed	Batch	Analyst
		Limit						
Client Sample ID: C35-1						Matrix: Drinking Water		
Collection Date: 9/7/2017 7:19:00AM					Last Time Used: 9/6/2017 9:00:00PM	Lab ID: 1710351-67		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:32	B710450	AG
Client Sample ID: C35-2						Matrix: Drinking Water		
Collection Date: 9/7/2017 7:20:00AM					Last Time Used: 9/6/2017 9:00:00PM	Lab ID: 1710351-68		
Collection Volume: 250 ml bottle								
Metals by ICP-MS								
Method: E200.8								
Lead	< 2.00	2.00	U	ppb		09/14/17 15:33	B710450	AG

Qualifiers and Definitions

Item	Description
U	Analyte included in the analysis, but not detected
%Rec	Percent Recovery

Certified Analyses included in this Report

Analyte	CAS #	Certifications
E200.8 in Drinking Water		
Lead	7439-92-1	ILEPA

List of Certifications

Code	Description	Number	Expires
AKDEC	State of Alaska, Dept. Environmental Conservation	UST-105	07/16/2017
CPSC	US Consumer Product Safety Commission, Accredited by PJLA Lab No. 1050	L14-56	04/30/2018
DoD	Department of Defense, Accredited by PJLA	L14-55	04/30/2018
ILEPA	State of Illinois, NELAP Accredited Lab No. 100256	003674	08/08/2018
ISO	ISO/IEC 17025, Accredited by PJLA	L14-56	04/30/2018
LELAP	State of Louisiana, NELAP Accredited Lab No. 171344	05015	06/30/2017
NJDEP	State of New Jersey, NELAP Accredited Lab No. IL010	NLC160001	06/30/2017
WDNR	State of Wisconsin Dept of Natural Resources	999888890	08/31/2017

CHAIN OF CUSTODY

Page 1 of 2
 COC Number _____
 Lab Work Order Number _____

Phone: 47-324-3320
 Fax: 847-967-6735



1710351
 PM: Tim Witrzek
 South Holland School District 151
 Drinking Water Analysis



Client Name South Holland School District 151	Project Name SHSD151
Client Contact Warren Chestans	Project Number If applicable
Address 155 + 7th Ave	Project Description Coolidge School
City Phoenix	PO Number
State/Zip IL	Shipped By
Phone 208-232-9410	Tracking Number
Fax	Tracking Number
Sampler Warren Chestans	Sampler Signature <i>[Signature]</i>

Requested Turn Around
Rush requests subject to additional charge.
Rush requests subject to lab approval.
Standard (days) 7
Expedited (days)
Due Date

Sample Name or Field ID	Sampled Date	Sampled Time	Sample Type Code	Matrix Code	Container Count	Preservation Code	Sample Comments
C1-1 First Draw	9-7	6:30AM	Grab	DW	1		01A 02A
C1-2 Second Draw	9-7	6:30AM					02A 03A
C2-1 1st	9-7	6:34AM					03A 04A
C2-2 2nd	9-7	6:34AM					04A 05A CR UNIT
C3-1 1st	9-7						
C3-2 2nd	9-7						
C4-1 1st	9-7	6:38AM					05A
C4-2 2nd	9-7	6:38AM					06A
C5-1 1st	9-7	6:40AM					07A
C5-2 2nd	9-7	6:40AM					08A
C6-1 1st	9-7	6:42AM					09A

Relinquished By <i>[Signature]</i>	Date/Time 9-17-17 1:25PM	Received By <i>[Signature]</i>	Date/Time 9/17/17 16:20
Relinquished By <i>[Signature]</i>	Date/Time 9/17/17 16:20	Received By <i>[Signature]</i>	Date/Time 9/17/17 16:20
Relinquished By <i>[Signature]</i>	Date/Time 9/17/17 16:20	Received By <i>[Signature]</i>	Date/Time 9/17/17 16:20
Sample Kit Prepared By Tim Witrzek	Date/Time 09/17/17 13:25	Comments Time of last water use at the facility -	Date/Time 9-6-17 9:00 PM

Client Name: South Holland School District 151
 Client Contact: Warren Chestans
 Address: 155 + 7th Ave
 City: Phoenix
 State/Zip: IL
 Phone: 208-232-9410
 Sampler: Warren Chestans

Project Name: SHSD151
 Project Description: Coolidge School
 PO Number: _____
 Shipped By: _____
 Tracking Number: _____
 Tracking Number: _____
 Sampler Signature: *[Signature]*

Requested Turn Around: Standard (days) 7
 Expedited (days): _____
 Due Date: _____

Sample Name or Field ID: C1-1 First Draw, C1-2 Second Draw, C2-1 1st, C2-2 2nd, ~~C3-1 1st~~, ~~C3-2 2nd~~, C4-1 1st, C4-2 2nd, C5-1 1st, C5-2 2nd, C6-1 1st

Sampled Date/Time: 9-7 6:30AM, 9-7 6:30AM, 9-7 6:34AM, 9-7 6:34AM, 9-7, 9-7, 9-7 6:38AM, 9-7 6:38AM, 9-7 6:40AM, 9-7 6:40AM, 9-7 6:42AM

Sample Type Code: Grab

Matrix Code: DW

Container Count: 1

Preservation Code: _____

Sample Comments: 01A 02A, 02A 03A, 03A 04A, 04A 05A CR UNIT, 05A, 06A, 07A, 08A, 09A

Relinquished By: *[Signature]*, *[Signature]*, *[Signature]*
 Date/Time: 9-17-17 1:25PM, 9/17/17 16:20, 9/17/17 16:20

Received By: *[Signature]*, *[Signature]*, *[Signature]*
 Date/Time: 9/17/17 16:20, 9/17/17 16:20, 9/17/17 16:20

Sample Kit Prepared By: Tim Witrzek
 Date/Time: 09/17/17 13:25
 Comments: Time of last water use at the facility -
 Date/Time: 9-6-17 9:00 PM

Cooler Numbers and Temperatures: 5.2

Matrix Codes: DW= Drinking Water, 3= Nitric Acid < 2, Store at 4 C



CHAIN OF CUSTODY

Page 2 of 7
COC Number
Lab Work Order Number

Environmental Monitoring and Technologies
8100 Austin Ave
Morton Grove
IL, 60053-3203

Phone: 47-324-3320
Fax: 847-967-6735

Client Name Spaeth Holland School District 151	Project Name SHSD151	Requested Turn Around
Client Contact Warren Chestang	Project Number If applicable	Rush requests subject to additional charge.
Address 155th + 7th Ave.	Project Description Coolidge School	Rush requests subject to lab approval.
City Phoenix	PO Number If applicable	7
State/Zip IL.	Shipped By If applicable	Standard (days)
Phone 708-732-9410	Tracking Number If applicable	Expedited (days)
Sampler Warren Chestang	Sampler Signature <i>[Signature]</i>	Due Date

Requested Analyses

200.8 - Lead

Sample Name or Field ID	Sampled Date	Sampled Time	Sample Type Code	Matrix Code	Container Count	Preservation Code	Sample Comments
C6-2 2nd	9-7	6:42AM	Grab	DW	1		10A
C7-1 1st	9-7	6:44AM					11A
C7-2 2nd	9-7	6:44AM					12A
C8-1 1st	9-7	6:45AM					13A
C8-2 2nd	9-7	6:45AM					14A
C9-1 1st	9-7	6:47AM					15A
C9-2 2nd	9-7	6:47AM					16A
C10-1 1st	9-7	6:49AM					17A
C10-2 2nd	9-7	6:49AM					18A
C11-1 1st	9-7	6:50AM					19A
C11-2 2nd	9-7	6:50AM					20A

Relinquished By <i>[Signature]</i>	Date/Time 09/11/17 13:25	Received By <i>[Signature]</i>	Date/Time 09/11/17 05:25	Sample Kit Prepared By Tim Witrzek	Date/Time
Relinquished By <i>[Signature]</i>	Date/Time 09/11/17 1620	Received By <i>[Signature]</i>	Date/Time 09/11/17 1620	Comments Time of last water use at the facility -	
Relinquished By Cooler Numbers and Temperatures 5.2		Received By <i>[Signature]</i>	Date/Time 9/11/17 16:20		9-6-17 9:00 PM

Preserv. Codes: 3= Nitric Acid <2, Store at 4 C

DW= Drinking Water

Matrix Codes:

CHAIN OF CUSTODY

Page 3 of 7
 COC Number
 Lab Work Order Number

Environmental Monitoring and Technologies
 8100 Austin Ave
 Morton Grove
 IL, 60053-3203
 Phone: 47-324-3320
 Fax: 847-967-6735



Client Name South Holland School District 151	Project Name SHSD 151	Requested Turn Around Rush requests subject to additional charge. Rush requests subject to lab approval. 7
Client Contact Warren Chestang	Project Number If applicable	Standard (days)
Address 155th + 7th Ave	Project Description Coolidge School	Expedited (days)
City Phoenix	PO Number	Due Date
State/Zip IL	Shipped By	
Phone 708-732-9410	Tracking Number	
Fax	Requested Analyses	
Sampler Warren Chestang	Sampler Signature <i>Warren Chestang</i>	

Sample Name or Field ID	Sampled Date	Sampled Time	Sample Type Code	Matrix Code	Container Count	Preservation Code	Sample Comments
C12 1st	9-7	6:50 AM	Grab	DW	1	3	21A
C12 2nd	9-7	6:50 AM				1	22A
C13 1st	9-7	6:51 AM					23A
C13 2nd	9-7	6:51 AM					24A
C14 1st	9-7	6:52 AM					25A
C14 2nd	9-7	6:52 AM					26A
C15 1st	9-7	6:53 AM					27A
C15 2nd	9-7	6:53 AM					28A
C16 1st	9-7	6:54 AM					29A
C16 2nd	9-7	6:54 AM					30A
C17 1st	9-7	6:55 AM					31A

Relinquished By <i>[Signature]</i>	Date/Time 08/11/17 13:35	Received By <i>[Signature]</i>	Date/Time 09/11/17 13:25	Sample Kit Prepared By Tim Witrzek	Date/Time
Relinquished By <i>[Signature]</i>	Date/Time 09/11/17 16:20	Received By <i>[Signature]</i>	Date/Time	Comments Time of last water use at the facility -	
Relinquished By <i>[Signature]</i>	Date/Time	Received By <i>[Signature]</i>	Date/Time		9-6-17 9:00 PM

Cooler Numbers and Temperatures
 Matrix Codes: 5.2
 DW= Drinking Water
 Preserv. Codes: 3= Nitric Acid < 2, Store at 4 C



CHAIN OF CUSTODY

Environmental Monitoring and Technologies
 8100 Austin Ave
 Morton Grove
 IL, 60053-3203

Page 4 of 7
 COC Number
 Lab Work Order Number

Phone: 47-324-3320
 Fax: 847-967-6735

Client Name <i>South Holland School District 151</i>	Project Name <i>SHSD 151</i>	Requested Turn Around
Client Contact <i>Warren Chestang</i>	Project Number	Rush requests subject to additional charge.
Address <i>155 E 7th Ave</i>	Project Description <i>Poolside School</i>	Rush requests subject to lab approval.
City <i>Phoenix</i>	PO Number	7
State/Zip <i>IL 60426</i>	If applicable	Standard (days)
Phone <i>(708) 732-9410</i>	Shipped By	Expedited (days)
Fax	If applicable	Due Date
Sampler <i>Phillip Neal</i>	Tracking Number	
	If applicable	
	Sampler Signature <i>Phillip Neal</i>	

200.8 - Lead

Sample Name or Field ID	Sampled Date	Sampled Time	Sample Type	Matrix Code	Container Count	Preservation Code	Sample Comments
C17-2 2nd	9-7	6:55 AM	Grab	DW	1		22A
C18-1 1st	9-7	6:56 AM					33A
C18-2 2nd	9-7	6:56 AM					34A
C19-1 1st	9-7	6:30 AM					35A
C19-2 2nd	9-7	6:31 AM					36A
C20-1 1st	9-7	6:32 AM					37A
C20-2 2nd	9-7	6:33 AM					38A
C21-1 1st	9-7	6:34 AM					39A
C21-2 2nd	9-7	6:35 AM					40A
C22-1 1st	9-7	6:35 AM					41A
C22-2 2nd	9-7	6:37 AM					42A

Relinquished By <i>[Signature]</i>	Date/Time 09/11/17 13:25	Received By <i>[Signature]</i>	Date/Time 09/11/17 13:25	Sample Kit Prepared By Tim Witrzek	Date/Time
Relinquished By	Date/Time 09/11/17 16:20	Received By	Date/Time	Comments Time of last water use at the facility -	
Relinquished By	Date/Time	Received By <i>[Signature]</i>	Date/Time 9/11/17 16:00		9/6/17 9 PM
Cooler Numbers and Temperatures					

Preserv. Codes: 3= Nitric Acid < 2, Store at 4 C

DW= Drinking Water

Matrix Codes:



CHAIN OF CUSTODY

Environmental Monitoring and Technologies
 8100 Austin Ave
 Morton Grove
 IL, 60053-3203

Phone: 47-324-3320
 Fax: 847-967-6735

Page 5 of 7
 COC Number
 Lab Work Order Number

Client Name South Holland School District 151	Project Name SHSD 151	Requested Turn Around Rush requests subject to additional charge. Rush requests subject to lab approval.
Client Contact Warren Chestans	Project Number If applicable	Standard (days) 7
Address 155 S 7th Ave	Project Description Coolidge School	Expedited (days)
City Phoenix	PO Number If applicable	Due Date
State/Zip IL 60426	Shipped By If applicable	
Phone (708) 732-9410	Tracking Number If applicable	
Sampler Phillip Deal	Sampler Signature <i>Phillip Deal</i>	

200.8 - Lead

Sample Name or Field ID	Sampled Date	Sampled Time	Sample Type Code	Matrix Code	Container Count	Preservation Code	Sample Comments
C 23-1 1st	9/7	6:40 AM	Grab	DW	1		43A
C 23-2 2nd	9/7	6:41 AM					44A
C 24-1 1st	9/7	6:41 AM					45A
C 24-2 2nd	9/7	6:42 AM					46A
C 25-1 1st	9/7	6:46 AM					47A
C 25-2 2nd	9/7	6:47 AM					48A
C 26-1 1st	9/7	6:48 AM					49A
C 26-2 2nd	9/7	6:49 AM					50A
C 27-1 1st	9/7	6:53 AM					51A
C 27-2 2nd	9/7	6:54 AM					52A
C 28-1 1st	9/7	6:58 AM					53A

Relinquished By <i>Phillip Deal</i>	Date/Time 09/17/17 13:35	Received By <i>[Signature]</i>	Date/Time 09/17/17 13:35	Sample Kit Prepared By Tim Witrzek	Date/Time
Relinquished By	Date/Time 09/11/17 16:20	Received By	Date/Time	Comments Time of last water use at the facility -	
Relinquished By	Date/Time	Received By <i>[Signature]</i>	Date/Time 9/11/17		9/10/17 9pm

Matrix Codes: DW= Drinking Water 3= Nitric Acid < 2, Store at 4 C



CHAIN OF CUSTODY

Environmental Monitoring and Technologies
 8100 Austin Ave
 Morton Grove
 IL, 60053-3203

Phone: 47-324-3320
 Fax: 847-967-6735

Page 6 of 7

COC Number
 Lab Work Order Number

Client Name <i>South Holland School District 151</i>	Project Name <i>SHSO 151</i>	Requested Turn Around Rush requests subject to additional charge. Rush requests subject to lab approval. 7 Standard (days) Expedited (days) Due Date
Client Contact <i>Warren Chestang</i>	Project Number If applicable	
Address <i>155th & 7th Ave</i>	Project Description <i>Coalbury School</i>	
City <i>Phoenix</i>	PO Number If applicable	
State/Zip <i>IL 60426</i>	Shipped By If applicable	
Phone <i>(708) 732-9400</i>	Tracking Number If applicable	
Fax	Sampler Signature <i>Phillip Neal</i>	

200.8 - Lead

Sample Name or Field ID	Sampled Date	Sampled Time	Sample Type Code	Matrix Code	Container Count	Preservation Code	Sample Comments
C-28-22nd	9/7	6:58AM	Grab	DW	1		54A
C-29-11st	9/7	6:59AM					50A
C-29-22nd	9/7	7:00AM					56A
C-30-7th	9/7	7:03AM					57A
C-30-22nd	9/7	7:04AM					58A
C-31-11st	9/7	7:05AM					59A
C-32-22nd	9/7	7:07AM					60A
C-32-11st	9/7	7:09AM					61A
C-32-22nd	9/7	7:10AM					62A
C-33-11st	9/7	7:15AM					63A
C-33-22nd	9/7	7:16AM					64A

Relinquished By <i>[Signature]</i>	Date/Time 8/16/17 18:25	Received By <i>[Signature]</i>	Date/Time 9/6/17 16:20	Sample Kit Prepared By Tim Witzek	Date/Time 9/6/17 9pm
Relinquished By		Received By		Comments Time of last water use at the facility -	
Relinquished By		Received By <i>[Signature]</i>			
Cooler Numbers and Temperatures			Matrix Codes: 5.2		

Preserv. Codes: 3= Nitric Acid < 2, Store at 4 C

DW= Drinking Water



CHAIN OF CUSTODY

Environmental Monitoring and Technologies
 8100 Austin Ave
 Morton Grove
 IL, 60053-3203

Phone: 47-324-3320
 Fax: 847-967-6735

Page 7 of 7
 COC Number
 Lab Work Order Number

Client Name South Holland School District 151	Project Name SHSD 151	Requested Turn Around
Client Contact Warren Chestang	Project Number If applicable	Rush requests subject to additional charge.
Address 155th & 7th Ave	Project Description Coolidge School	Rush requests subject to lab approval.
City Phoenix	PO Number	7
State/City IL 60476	Shipped by	Standard (days)
Phone (708) 732-9410	If applicable	Expedited (days)
Fax	Tracking Number	Due Date
Sampler Phillip Neal	If applicable	
	Sampler Signatures <i>Phillip Neal</i>	

Sample Name or Field ID	Sampled Date	Sampled Time	Sample Type Code	Matrix Code	Container Count	Preservation Code	Sample Comments
C34-1	9/7	7:17 AM	Grab	DW	1	3	65A
C34-2	9/7	7:18 AM	↓	↓	↓	1	66A
C35-1	9/7	7:19 AM	↓	↓	↓	↓	67A
C35-2	9/7	7:20 AM	↓	↓	↓	↓	68A

Received By <i>[Signature]</i>	Date/Time 09/11/17 13:25	Received By <i>[Signature]</i>	Date/Time 09/14/17 12:25	Sample Kit Prepared By Tim Wirtzek	Date/Time
Acquired By <i>[Signature]</i>	Date/Time 09/11/17 16:20	Received By <i>[Signature]</i>	Date/Time	Comments Time of last water use at the facility -	
Relinquished By <i>[Signature]</i>	Date/Time	Received By <i>[Signature]</i>	Date/Time	9/6/17	9 PM

Matrix Codes: 5C
 DW= Drinking Water
 Preserv. Codes: 3= Nitric Acid < 2, Store at 4 C